



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.effectis.com

# DECLARATION OF TEST RESULTS

No: ERA – 2200 – 0003

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 4<sup>th</sup> of February 2022. Classification of reaction to fire has been carried out in accordance the standard:

**EN 13501-1:2018**

## “Polyethylene Coating Insulation Pipe”

| Fire behaviour |   | Smoke production |   | Flaming droplets |
|----------------|---|------------------|---|------------------|
| B <sub>L</sub> | - | s                | 1 | , d 0            |

### Flammability Classification\*

**Hardly inflammable**

Placed on the market by: ANADOLU BAKIR A.Ş.  
Mimar Sinan Mah. Eski Silivri Cad. No:20/1 34535 Büyükçekmece,  
İstanbul / TURKEY

Manufactured by: ANADOLU BAKIR A.Ş.  
Mimar Sinan Mah. Eski Silivri Cad. No:20/1 34535 Büyükçekmece,  
İstanbul / TURKEY

Ali BAYRAKTAR  
Laboratory Manager  
25.02.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-22-042

